



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2025/NDZ/ 1327

Dated: 19/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Little Flowers International School located at C-11, 12 (100 feet Road), Kabir Nagar, Delhi-110094, comprised of Basement, Ground plus two upper floors (Old Bldg.) and Ground plus three upper floors (New Bldg.) owned/occupied by Little Flowers International School was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/513 dated 12/05/2022. The premises was re-inspected by the officer concerned of this department on 17/09/2025 in the presence Sh. R. K. Dua (Chairman) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 19/11/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010& also conditions printed below.

Issued on.....19/11/2025.....at New Delhi by.

(Dr. S. K. TOMAR)  
DY. CHIEF FIRE OFFICE (NDZ)  
DELHI FIRE SERVICE

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Chairman, Little Flowers International School located at C-11, 12 (100 feet Road), Kabir Nagar, Delhi-110094

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per BBL.

Voonmi Jain  
Manager  
Little Flowers International School  
C-11-12, (100 Ft. Road), Kabir Nagar,  
Shahdara, Delhi-94

Shane  
Vice Principal  
Little Flower's International School  
C-11-12, (100 Ft. Road) Kabir Nagar  
Shahdara, Delhi-110094